






GROUT INJECTION SPECIALISTS

	JOB DESCRIPTION Kensal Road, NW10	JOB No: 5600 DATE: 18/23 Jan 2207
OBJECTIVE:	Leak sealing to basement car park, car park access ramp and boiler room.	
TECHNICAL DATA:	DRILLING:	POLYMERISATION TIME: 40 seconds
	DIAMETER: 16mm CENTRES: 3-400mm ANGLES: 30-40 deg DEPTH: 250mm	INJECTION PRESSURE: 90-120 bar
		MATERIALS: TAM PUR 150 TAM PLUG
COMMENTS: Water ingress was evident along the wall/slab joint of the rear car park wall. There were also signs of water ingress along areas of vertical joints. The nearside walkway of the access ramp showed evidence of leakage from the wall/slab joint beneath the pathway. The joint was also leaking below into the plant room. The rear corner joint of the plant room was also showing signs of heavy water ingress. All areas were successfully treated with Tam Pur 150 in conjunction with a single piston electric pump.		
PRIOR TO TREATMENT:		
<div style="display: flex; justify-content: space-around;">   </div>		
COMPLETED WORKS:		
<div style="display: flex; justify-content: space-around;">   </div>		

GROUT INJECTION SPECIALISTS LTD
UNIT 12 BLACK MOOR BUSINESS Pk, NEW Rd,
MAULDEN, BEDFORDSHIRE.
MK45 2BZ
01525 404770

WWW.GROUTINJECTIONSPECIALISTS.CO.UK


APPROVED CONTRACTOR


APPROVED CONTRACTOR